



# Purchasing and Central Services

Monroe County, New York

**Maggie Brooks**  
*County Executive*

**Dawn C. Staub**  
*Purchasing Manager*

**ADDENDUM NO:** 1

**BID PROJECT NO:** 0316-12 BOARDWALK DECKING & FASTENERS –  
Ontario Beach Park

**DATE:** March 28, 2012


---

BIDDERS PLEASE NOTE:

**ATTACHED PAGE IS CLARIFICATION TO QUESTIONS ON THE BID SPECIFICATIONS.**

SIGN this Addendum below acknowledging receipt and understanding and INSERT in bid document.

**MONROE COUNTY**

  
Greg Hart, Buyer  
(585) 753-1135

---

The undersigned bidder acknowledges receipt and understanding of Addendum No. 1 to Bid Project No. 0316-12 BOARDWALK DECKING & FASTENERS – Ontario Beach Park.

\_\_\_\_\_, 2012  
Date

\_\_\_\_\_  
Name of Company

\_\_\_\_\_  
Authorized Signature

\_\_\_\_\_  
Title

**Question #1** Does the Decking Material 3x8x12 Need to be KDAT (Kiln Dried After Treatment)?

**Answer** No.

**Question #2** The Decking must be radius Edged not square & flat?

**Answer** ¼" radius edge as per section 2.1.

**Question #3** Delivery of Product. Can this be made at one time or in stages? (Freight has become tight and we would like to plan if one of our customers wins the bid).

**Answer** Delivery must be in stages with 25% of the order within 6 weeks and the balance to be coordinated with Monroe County as per Terms and Conditions page 3.

**Question #4** Fasteners must they be Stainless Steel or Equivalent?

**Answer** Fasteners must be GRK RSS structural screws made of carbon steel as per section 2.2.

**Question #5** Is 19% maximum moisture content measured before treating?

**Answer** Yes

**Question #6** Is MCA- Micronized Copper Azole- UC4A ground contact an acceptable treatment?

**Answer** As long as the treatment meets section 2.4 of the specifications it would be acceptable.

**Question #7** Does the Contractor have to off-load the product?

**Answer** Add to Section 1.5 "Contractor to provide product unloaded to ground level".